

Table 5.34 — Places of public assembly – Public car parks (indoor)

Ref. no.	Type of area, task or activity	\bar{E}_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.34.1	In/out ramps (during the day)	300	25	0,40	40	1. Illuminances at floor level. 2. Safety colours shall be recognisable.
5.34.2	In/out ramps (at night)	75	25	0,40	40	1. Illuminances at floor level. 2. Safety colours shall be recognisable.
5.34.3	Traffic lanes	75	25	0,40	40	1. Illuminances at floor level. 2. Safety colours shall be recognisable.
5.34.4	Parking areas	75	-	0,40	40	1. Illuminances at floor level. 2. Safety colours shall be recognisable. 3. A high vertical illuminance increases recognition of peoples faces and therefore the feeling of safety.
5.34.5	Ticket office	300	19	0,60	80	1. Reflections in the windows shall be avoided. 2. Glare from outside shall be prevented.

Table 5.35 — Educational premises – Nursery school, play school

Ref. no.	Type of area, task or activity	\bar{E}_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.35.1	Play room	300	22	0,40	80	High luminances should be avoided in viewing directions from below by use of diffuse covers.
5.35.2	Nursery	300	22	0,40	80	High luminances should be avoided in viewing directions from below by use of diffuse covers.
5.35.3	Handicraft room	300	19	0,60	80	