



- Notes:
- Perpendicularity of whole external cabinets: $\ll=0.5\text{mm}$
 - Planeness of front panel : $\ll 1.2\text{mm}$
 - Ingress Protection: Front IP65 , Rear IP54
 - The dimension which haven't showed *base on GB1804-M
 - The painting on both inner and outside cabinets should be based on requirements.
 - Locating pin and cabinets should conductive
 - Door key and cabinets door should conductive

MODEL	AI2588 (1500X1200X150)	
DSGN	DATE	2011/xx/xx
CHKD	DATE	
APPD	DATE	
Projection Sign		

Rev.	Zone	CHANGE DESCRIPTION	DRFT BY	CHKD BY	DATE
		NAME	SCALE 1:1		ECN NO.
		Cabinet Assembly Drawing	QTY.	DWG NO. A4	
		REV. A	SHT	OF	
		MATERIAL	DWG NO.		PANEL NO.
		SPCC T=1.2mm			